



Taylors Bridge Service Record Self Contained Breathing Apparatus (SCBA) Checklist

Date _____

| Documentation Legend: | | | | | | | | | | | | | | | | | |
|--------------------------------------|--------------------|---|---|---|---|---|-------------------|---|---|----|----|----|----|----|----|----|----|
| Adjustments Made (X) | Repairs Needed (O) | | | | | | Satisfactory (OK) | | | | | | | | | | |
| | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 |
| Service Requirements | | | | | | | | | | | | | | | | | |
| AIR TANKS: 4000 PSI TO 4500 PSI | | | | | | | | | | | | | | | | | |
| ALL STRAPS FULLY EXTENDED | | | | | | | | | | | | | | | | | |
| VALVE CUT OFF AT TANK | | | | | | | | | | | | | | | | | |
| HOSE IN GOOD CONDITION | | | | | | | | | | | | | | | | | |
| FACE MASK - CLEAN | | | | | | | | | | | | | | | | | |
| BYPASS (RED VALVE) OFF | | | | | | | | | | | | | | | | | |
| EMERGENCY ALARM BELL WORKING | | | | | | | | | | | | | | | | | |
| CHECK DONNING DEVISE | | | | | | | | | | | | | | | | | |
| MOUTH PIECE OUT OF HOLDER | | | | | | | | | | | | | | | | | |
| CHECKLIST PERFORMED LAST WEEK | | | | | | | | | | | | | | | | | |
| BATTERY TEST | | | | | | | | | | | | | | | | | |
| LOCATION OF SCBA | | | | | | | | | | | | | | | | | |
| Checked By | | | | | | | | | | | | | | | | | |
| Officer's Initials (Required) | | | | | | | | | | | | | | | | | |

Before re-packing SCBA, breath down the regulator. Don't leave pressure on the regulator!!

Annual Service Test: NOVEMBER

Change Batteries: April and October

Comments _____
